

TOWN OF SOMERS

Department of Health
600 Main St.
Somers, CT 06071
(860) 763-8216

FEE: \$150.00

DUE

REVIEW OF SITE PLAN FOR A SUBSURFACE SEWAGE DISPOSAL SYSTEM ON:
279 Billings Rd., SOMERS, CT

TO: Ronald Bilodeau
349 West Wakefield Blvd.
Winsted, CT 06098

DESIGNER: T. Coon, P.E.
DATE OF PLAN: 12/6/21
REVISED TO: Rev. 12/10/21

REASON FOR SUBMISSION

- HIGH GROUNDWATER LEVEL
 SHALLOW BEDROCK
 EXCESSIVE SLOPE
 RESTRICTIVE SOIL HORIZON
 NEW CONSTRUCTION () REPAIR
 OTHER Wetlands

DESIGN SPECIFICATIONS

ESTIMATED FLOW: 3 bdrm DESIGN PERC. RATE: 6-10 MIN./IN.
SEPTIC TANK: 1500 GALS. LEACHING SYSTEM: 590 SQ. FT.
FILL SYSTEM: ±1.5 FT. 100 L.F. x 12" Galleries
CURTAIN/FOOTING DRAIN: NONE OTHER: _____

ACTION:

- APPROVAL
 APPROVAL WITH MODIFICATIONS OR PROVISIONS NOTED
 APPROVAL DENIED - SITE UNSUITABLE FOR AS IT PRESENTLY EXISTS
 APPROVAL DENIED - INSUFFICIENT INFORMATION ON PLAN
 APPROVAL DENIED - REVISE AS NOTED

COMMENTS: 1. Design Engineer shall stake out house
+ System location/elevations and plan w/ benchmark
shall be submitted prior to issue of a Building Permit.
2. Submit Field Sheet for perc. rate shown on plan.
3. Final Plan must have Soil Scientist signature.
4. Elevation Certificate required prior to issue of
Certificate of Occupancy for property.
5. \$150.00 Plan Review Fee must be paid prior to issue
of a Building Permit.

COPIES TO:

- BUILDING OFFICIAL
 TOWN ENGINEER
 ZONING OFFICER
 WETLANDS OFFICER
 APPLICANT
 ENGINEER
 OTHER

SINCERELY,


STEVEN JACOBS
REGISTERED SANITARIAN

DATE 12/21/21