

TOWN OF SOMERS

Department of Health

600 Main St.

Somers, CT 06071

(860) 763-8216

10/6/20

Aeschliman Land Surveying, PC
1379 Main St.
East Hartford, CT 06108
Attn: S. Aeschliman

RE: Somers, CT
186 Stebbins Rd.
Proposed Subdivision
Jones Property

Dear Mr. Aeschliman:

I have reviewed the preliminary plans dated 7/30/20 for the proposed subdivision of the above referenced property. The following are my comments:

1. The Town of Somers, Gillettes Brook Floodplain Management Study, dated Sept. 2003 indicates a Base Flood Elevation, BFE of approx. 279.0 at the downstream side of Battle St. and approx. 276.0 at the western reach of the property, (see attached). Correct the BFE's shown and adjust the flood zone accordingly. If other methods/calculations were used, please submit for review.
2. Provide the attached Well Water Disclaimer on the Subdivision Plan.
3. Soil Scientist signature required on plans.
4. Final plans must signed & sealed by the Design Engineer.
5. A Subdivision Plan Review fee of: (1 lots x \$100.00 = \$100.00), must be paid prior to final approval.

Please submit revised plans at your earliest convenience. Do not hesitate to call my office if you have any questions in regards to this matter.

Sincerely



Steven Jacobs
Registered Sanitarian

Cc Somers Planning Comm.
J. Roy, ZEO
J. Shapiro, W.O.
J. Jones

**GILLETTES BROOK
FLOODPLAIN MANAGEMENT STUDY UPDATE
SOMERS, CONNECTICUT**

**Conversion of Hydraulic Model
from WSP2 to HEC-RAS**

**Report to
Town of Somers**

**In Fulfillment of
Agreement No. A-67-1106-3-013
between the Town of Somers & USDA, NRCS**

**Lesley Sweeney, Environmental Engineer
Benjamin Smith, Hydrologist
USDA, Natural Resources Conservation Service
344 Merrow Road, Suite A
Tolland, CT 06084**

This report may be cited as follows:

Sweeney, Lesley; Smith, Benjamin. 2003. Gillettes Brook Floodplain Management Study Update Somers, Connecticut. CT-TP-2003-5. USDA, Natural Resources Conservation Service, Tolland, CT.

CT-TP-2003-5
September 2003